



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Little Silver Point Rd School, 357 Point Rd., Little Silver, NJ
PAS Project ID : P21-13699

Matrix : Drinking Water
Report Date : 1/10/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P21-13699-01	Field Blank L/S Pt Rd School	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:43	1/4/22 12:47
P21-13699-02	1 DW Hall	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:44	1/4/22 12:50
P21-13699-03	2 WC 103 TL	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:45	1/4/22 13:25
P21-13699-04	3 FP 103 TL	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:46	1/4/22 13:28
P21-13699-05	4 DW 120	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:47	1/4/22 13:32
P21-13699-06	7 DW 121	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:49	1/4/22 13:36
P21-13699-07	9 DW 124	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:50	1/4/22 13:39
P21-13699-08	10 DW 125	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:52	1/4/22 13:43
P21-13699-09	13 DW 122	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:54	1/4/22 13:47
P21-13699-10	14 DW 123	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:56	1/4/22 14:07
P21-13699-11	15 DW Hall	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 08:00	1/4/22 14:11
P21-13699-12	16 DW Hall	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 08:03	1/4/22 14:18
P21-13699-13	17 DW Hall	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 08:06	1/4/22 14:22
P21-13699-14	18 Sink 204 Kitchen	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 08:08	1/4/22 14:26
P21-13699-15	19 Sink 209 Nurse	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 08:11	1/4/22 14:29
P21-13699-16	20 Sink 209 Nurses Bathroom	Lead	4.42	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 08:12	1/4/22 14:33
P21-13699-17	21 Sink 209 Low	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 08:13	1/4/22 14:37
P21-13699-18	22 DW Outside	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 08:02	1/4/22 15:57

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Little Silver Markham Place, 95 Markham Place, Little Silver, NJ
PAS Project ID : P21-13698

Matrix : Drinking Water
Report Date : 1/7/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P21-13698-01	Field Blank Markham Place	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 06:59	1/4/22 15:07
P21-13698-02	1 MP1 DW Hall WC	Lead	1.44 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:00	1/4/22 15:55
P21-13698-03	2 MP2 Sink Office	Lead	0.970 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:02	1/4/22 16:03
P21-13698-04	3 MP3 Nurses Sink Bathroom	Lead	1.44 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:03	1/4/22 16:07
P21-13698-05	4 MP4 Kitchen FP	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:04	1/4/22 16:11
P21-13698-06	5 MP5 DW Hall 5/6 WC	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:07	1/4/22 16:15
P21-13698-07	6 MP6 DW Hall 10/12 WC	Lead	1.44 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:09	1/4/22 16:19
P21-13698-08	7 MP7 DW Hall 18 WC	Lead	2.36	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:12	1/4/22 16:23
P21-13698-09	8 MP8 FP TL 113	Lead	2.13	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:13	1/4/22 16:27
P21-13698-10	9 MP9 TL WC Cooler Bsmt	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:14	1/4/22 16:46
P21-13698-11	10 MP10 TL FP Bsmt	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:15	1/4/22 16:54
P21-13698-12	11 MP11 DW 2nd Floor WC	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:17	1/4/22 16:58
P21-13698-13	12 MP12 DW Gym 2005	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:21	1/4/22 17:02
P21-13698-14	13 MP13 DW Gym 2005	Lead	31.4	ug/L	5	10.0	4.50	15.0 *	SM 3113 B	12/30/21 07:22	1/4/22 17:44
P21-13698-15	14 MP14 DW Hall 2005 WC	Lead	12.3	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:23	1/4/22 17:06
P21-13698-16	15 MP15 Art Room 14A DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:25	1/4/22 17:15
P21-13698-17	16 MP16 Music Room DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	12/30/21 07:30	1/4/22 17:19

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feltson, Lab. Director